

INDIAN INSTITUTE OF TECHNOLOGY GOA

At Goa College of Engineering Campus, Farmagudi, Ponda, Goa-403401

CONSTRUCTION & ESTATE MANAGEMENT DIVISION

GSTIN: 30AABAI1653D1ZF

PAN: AABAI1653D

TAN: BLRI08261B

Enquiry No: C&EMD/ IITGOA/2020/010

Dt.08/06/2020

NOTICE INVITING QUOTATION

IIT Goa invites sealed quotations from approved and eligible contractors for three phase connection and the work of power circuit along with provision of earth pit near lab 7& 8. Item of work and schedule of quantities are as stated below.

Sr No.	Discription of Items	Unit	Qty	Rate	Amount
1	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed medium class PVC conduit as required. 2 X 6 sq. mm + 1 X 6 sq. mm earth wire.	R. M	35		
2	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed medium class PVC conduit as required. 1 x 16 sq. Mm (for both neutral and earthing)	R. M	40		
3	Supplying and fixing following way, horizontal type three pole and neutral, sheet steel, MCB distribution board, 415 V, on surface/ recess, complete with tinned copper bus bar, neutral bus bar, earth bar, din bar, interconnections, powder painted including earthing etc. as required. (But without MCB/RCCB/Isolator) 4 way (4 + 12), Double door.	Nos	1		
4	Supplying and fixing following rating, four pole, 415 V, isolator in the existing MCB DB complete with connections, testing and commissioning etc. as required. 40 A.	Nos	2		
5	Earthing with copper earth plate 600 mm X 600 mm X 3 mm thick including accessories, and providing masonry enclosure with cover plate having locking arrangement and watering pipe of 2.7 metre long etc. with charcoal/ coke and salt as required.	Nos	2		
6	Supplying and laying 25 mm X 5 mm copper strip on 0.5 metre below ground/surface as strip earth electrode, including connection/ terminating with nut, bolt, spring, washer etc. as required. (Jointing shall be done by overlapping and with 2 sets of brass nut bolt & spring washer spaced at 50mm)	R. M	60		

Make:

Cables: Finolex, Polycab, RR Cables
MCB & DB: Legrand, Havells, CNS

Terms and conditions:

1. Quotation must be valid for at least 60 days.
2. The contractor should Quote the price including all taxes & GST.
3. The work should be completed within a stipulated time of 21 days.
4. Scaffolding/ladder hiring and installation should be included in the work.
5. The agency must have all toolkits, spares and other required materials to carry out the work.
6. The work shall be carried out strictly in accordance with the terms, conditions and specifications as per CPWD norms, in the approved workmanlike manner and as per standard practice.
7. Materials required for satisfactory completion of work shall be of approved quality, make, grade etc. and of/or confirming to the Indian Standard Specifications (Latest revision) wherever applicable and approved by the Engineer-in-charge.
8. The work shall be carried out strictly in accordance with the terms, conditions and specifications as per norms, in the approved workmanlike manner and as per standard practice.
9. Payment will be done on satisfactory completion of the work.
10. For any clarification, you may kindly contact Mr. Saptesh Pandit, Junior Engineer (saptesh@iitgoa.ac.in)
11. All sealed quotations must reach to the C & EMD Office, IIT Goa, at Goa College of Engineering Campus, Farmagudi, Ponda, Goa by 15:00 Hrs on or before 15/06/2020.

Sd/-
(EE, C&EMD)