



**CORRIGENDUM**

**Date:** 13<sup>th</sup> of September 2022

**NIQ for SITC of Energy Meters at Various Locations in IIT Goa vide NIQ No.:  
IITGOA/C&EMD/2022/029 dtd. 12<sup>th</sup> of September 2022**

Following changes have been incorporated in the Notice Inviting Quotations.

**# 01. Section 1 ‘Notice Inviting Quotations’; Sub-Section 1.3 ‘Terms and Conditions’;**

1.3.19\*: All the Meters and CT’s must be tested and sealed by Goa Electricity Department and shall be accompanied with proper test certificates. Meter or CTs without test certificate shall not be accepted.

1.3.20\*: The bidder must inspect the site before putting up the bids. No additional amount shall be paid on account of site condition whatsoever.

**# 02. Section 2 ‘Schedule of Quantities’;**

Sr. No.	Particular	Unit	Qty	Rate	Amount
1.	Supply, installation, testing and commissioning of 3-Phase, 4-wire KWh meter LCD type - 240 Volts, -/5A, Acc. class 0.5s, 50 Hz energy meter, duly tested and sealed by Goa Electricity Department. <b>Note:</b> Test certificate must be submitted before installation. <b>Make:</b> L&T Cat No. WR301BC3C00 or equivalent.	Each	6		
2.	Supply, installation, testing and commissioning of CT’s of following ratios tested by Goa Electricity Department. <b>Note:</b> Test certificate must be submitted before installation.				
2.1	400 A/ 5 A	Each	3		
2.2	200 A/ 5 A	Each	9		
2.3	100 A/ 5 A	Each	6		
3.	Supplying and installation of painted M.S/G.I box with viewing glass for housing energy meter.	Each	6		
4.	Installation of C.T and energy meters with suitable wiring and accessories etc.	Each	6		
<b>Total</b>					

**Note:** 1) The Schedule of Quantities as given in this Corrigendum should be considered by the bidders while quoting for the NIQ.

2) The Schedule of Quantities given in the original NIQ may be discarded

**Sd/-  
Registrar, IIT Goa**